

ITP No. : _____
 Inspection Gr. : _____
 Report No. : _____
 Date : _____

FILED INSPECTION REPORT

Quality Control Form

Inspection Type : <div style="text-align: center;">INSPECTION EMERGENCY GENERATOR</div>	Work No. : _____ Unit No. : _____ Item No. : _____ Location : _____												
Inspection Notice No. : _____	Date / Names / Signature												
Drawing No(s) : _____	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 33%;">Company</th> <th style="width: 33%;">Contractor</th> <th style="width: 33%;">Subcontractor</th> </tr> <tr> <td style="text-align: center;">/ /</td> <td style="text-align: center;">/ /</td> <td style="text-align: center;">/ /</td> </tr> <tr> <td style="height: 20px;"> </td> <td> </td> <td> </td> </tr> <tr> <td style="height: 20px;"> </td> <td> </td> <td> </td> </tr> </table>	Company	Contractor	Subcontractor	/ /	/ /	/ /						
Company	Contractor	Subcontractor											
/ /	/ /	/ /											
J/B No. / Cabinet No. : _____													
Manufacture : _____													
_____ : _____													
_____ : _____													

1. Installation inspection :

No.	Item to Check	Result	Remarks
1	Check conformity of nameplate to specification.		
2	Check assembling layout and arrangement.		
3	Check generator baseplate with vendor print.		
4	Check leveling and grouting.		
5	Visual check of the cooling system for any leakage.		
6	Check extract line supported correct.		
7	Check painting of generator and baseplate.		
8	Check air inlet and ventilation of generator room correct.		
9	Check generator connection to emergency panel correct		
10	Check generator control panel supplied and installed as per specification.		
11	Check connection of earthing system.		

Remarks :