www.Inspection-for-Industry.com

FIELD INSPECTION REPORT Quality Control Form							ITP No.: Inspection Report No.:				
INSPECTION TYPE							WORK No.				
							UNIT NO.				
INSPECTION- LV OVERCURRENT / EARTH FAULT PROTECTION RELAY TEST							ITEM No.				
							LOCATION				
								DATE	/NAME	S/SIGNA	ATURE
INSPECTION NOTICE NO.:							COMPANY CONTRA			ACTOR	SUBCONTR
DRAWING NO(S):							/ ,	/	/	/	/ /
DEVICE TYPE:											
MANUFACTURER:											
TYPE:											
SECTION NO.:											
MOTOR FLC: Amp.							CONTEACTOR RATING				
TIP SETTING RANGE: Amp. TEST EQUIPMENT:							CONTACTOR RATING:				Amp.
Note: (1) Test in Italics are to be carried out under the supervision of Vendor Engineer as part of Pre-commissioning											
• • • • • • • • • • • • • • • • • • • •											
1. Primary Injection Test: All Selected Trip setting:A											
Test Current Operating Trip Time						ime (s)	s) Remarks				
Set (5)	Am	p.	Temp.				Actual All three ph		ases connected in series.		
300		Α	Cold		S		S				
300		<u>A</u>	Warm		S		S				
200 A Warm					s s s p time curve supplied by manufacturer.						
1voic. (2) Trip time curve supplied by manufacturer.											
2. PTC Relay (Positive Temperature Coefficient)											
Range (kΩ)			etting (kΩ)		Pick-Up Threshold Trip (kΩ)		Drop Out Threshold Reset (kΩ)			Remarks	
0 ~ 5.1			3.4 ~ 3.8								
3. Earth Fault Relay: (50G)											
Setting (A) Pick-Up Threshold							Remarks				
Setting (11)		Curve	(A) Actua	al (A)			Actual (S)		-		
			7 1								
4. Unbalance/ Loss of power (46): Applicable for MPR											
	At 2 x I				t 2 x Is Ø B					<u> </u>	
Setting (A)	Trip Cla		Ø A				. 1	ØC ()		A . 1	Remarks
		Ci	arve(s)	Actual	Curve(s)	P	Actual	Curve	e(s)	Actual	
5. Delay Setting after tests											
5. Relay Setting after test: 1. Thermal Relay: 2. Earth Fault Relay:											
3. Unbalanced Relay: 4. Setting Seald:											
6. Remarks and Deviations:											

Legend NA.: Not Applicable